

General Environmental Incident Summary

Incident: 4178 **Date/Time Notice:** 7/28/2016 0824 **DEM Incident No:**
Responsible Party: Farmers Union Oil
Date Incident: 7/28/2016 **Time Incident:** **Duration:** 0 days
County: Nelson **Twp:** 152 **Rng:** 58 **Sec:** 6 **Qtr:** SE
Lat: 48.02049 **Long:** -98.12402 **Method:** Interpolation from map
Location Description: Farmers Union Oil of Michigan; 113 South ST E, Michigan ND

Submitted By: Tom Haahr **Affiliation:** Farmers Union
Address: 600 Hwy 2 West
City: Devils Lake **State:** ND **Zip:** 58301

Received By: David Cameron Health
Contact Person: Tom Haahr
113 South Street E
Michigan, ND 58259

Distance Nearest Occupied Building: 5 Feet **Release Contained:** No

Type of Incident: Tank Leak

Description of Released Contaminant: gasoline odors from groundwater entering the stations basement

Volume Spilled: 0.00 gallons **Ag Related:** No

EPA Extremely Hazardous Substance: No **Reported to NRC:** No

Cause of Incident:

recent heavy rains elevated groundwater table such that water in basement sump has strong gasoline odor

Risk Evaluation:

possibly headaches from exposure to fumes

of Fatalities: 0 **# of Injuries:** 0 **Affected Medium:** 06 - water and air

Potential Environmental Impacts:

groundwater impacts to be determined

Action Taken or Planned:

Aboveground tanks at site and associated underground piping will be tested for integrity, store has been closed pending remediation of indoor air quality. ASTs are in cement impoundment which does not appear to have any impacts. Tanks and piping tests passed. Source believed to be old ust contaminated soils.

Wastes Disposal Location: to be determined

Agencies Involved:

Updates

Date: 7/28/2016 ***Status:*** Reviewed - Assigned to NDDoH Division

Author: Sues, Bill

Updated Volume:

Notes:

NDDoH Division of Waste Management - Underground Storage Tank Program has jurisdiction.